



- NOTES:
1. PINS 19 TO 20 SHORTED - SETPOINT 2 - 0° C
 PINS 19 TO 20 OPEN - SETPOINT 1 - OPERATING SETPOINT
 (BOTH CR216 & CR220 HAVE TO BE ENERGIZED FOR NORMAL OPERATION)
 2. GROUND THERMOCOUPLES AT CABINET END ONLY, AS DRAWN, NOT AT Y-CYLINDER END

A